

Adore floors ltd Unit 3 Broomhill Business Park 24 Dublin Ierland

your notice of

your ref.

our ref. JW/2748

date

Zwijnaarde, 2014-11-27

Comments on report 1404416

Dear,

On a sample pvc flooring, our reference T1415006 we performed static electrical propensity according test standard EN1815:1997. The standard prescribes that the customer needs to mention installation condition before test. If not the static electrical propensity is measured in worst case scenario = with rubber insulating mat.

Based on the obtained results in our test report with insulating mat it is sure that the product will fulfil requirement < 2kV if installed on concrete floor.

We hope having been helpful with this information.

Yours sincerely,

Dr. Jo Wynendaele

Consultant floor & wall coverings

